

## QUOTE SPECIFICATIONS

### PROJECT 1

#### **Replacing 4 split system units HVAC systems at Poplar Middle School Cafeteria.**

The Poplar Bluff R-1 School Dist. request quotes to furnish labor, equipment and materials to complete the following:

- Demo and remove existing HVAC equipment.
- Install 4 quantity 120,000 BTU 95% gas furnaces, 5 ton condensing units and evaporator coils.
- Install UV purifiers quantity as needed in AHUs with all associated controls and wiring.
- Install new refrigerant line sets.
- Install angle iron base wrapped with insulated sheet metal underneath all four furnaces
- Install new drains
- Install new thermostat and control wiring to operate all 4 furnaces at the same time.
- Rework supply ductwork from connection to ceiling to each furnace to allow for new base.
- Extend all necessary gas piping, wiring, etc. to accommodate
- Core holes in exterior block wall to allow for new concentric kits
- Install new venting
- Supply equipment spec sheets with quote
- District to retain existing units for training and salvage.

: If you have any questions, call Alan Ursery at the Maint. Department between 8:00 A.M. and 4:00 P.M. at 573-785-3338. or cell number 573-772-0050

## General Requirements

- Adhere to current Davis Bacon Wage Order and related Acts.
- Adhere to all Federal, State and local code
- Furnish certificate of liability insurance prior to starting work
- Work with other contractors and owner's schedules to complete
- Contractor responsible for permits and licenses that are required
- Contractor must have proof of at least 5 years of related experience
- Contractor responsible for cleanup and disposal of waste.
- Contractor responsible for measurement of project
- Contractor responsible for security and safety of project

The Poplar Bluff R-1 Schools District, by its authorized representatives, reserves the right to reject any or all bids, to select the lowest or best bid and to make decisions which they deem beneficial to the Poplar Bluff R-1 Schools District.

If you have any questions, call Alan Ursery at the Maint. Department between 8:00 am and 4:00 pm at 573-785-3338 or cell number 573-772-0050