

QUOTE SPECIFICATIONS

PROJECT 2

Installing 3 ductless split HVAC units at Poplar Middle School Gym Lobby

The Poplar Bluff R-1 School Dist. request quotes to furnish labor, equipment and materials to complete the following:

- Install 3 quantity 36,000 BTU Mitsubishi single zone heat pumps and 3 quantity 36,000 BTU Mitsubishi wall heads.
- Install UV purifiers quantity as needed in AHUs with all associated controls and wiring.
- Install 3 condensate pumps pumping to the exterior of the building.
- Install line sets with line hide in exposed areas.
- Install control wiring and line voltage from outdoor to indoor units
- Obtain license and permits as required
- Supply equipment spec sheets with quote

: If you have any questions, call Alan Ursery at the Maint. Department between 8:00 A.M. and 4:00 P.M. at 573-785-3338. or cell number 573-772-0050

General Requirements

- Adhere to current Davis Bacon Wage Order and related Acts.
- Adhere to all Federal, State and local code
- Furnish certificate of liability insurance prior to starting work
- Work with other contractors and owner's schedules to complete
- Contractor responsible for permits and licenses that are required
- Contractor must have proof of at least 5 years of related experience
- Contractor responsible for cleanup and disposal of waste.
- Contractor responsible for measurement of project
- Contractor responsible for security and safety of project

The Poplar Bluff R-1 Schools District, by its authorized representatives, reserves the right to reject any or all bids, to select the lowest or best bid and to make decisions which they deem beneficial to the Poplar Bluff R-1 Schools District.

If you have any questions, call Alan Ursery at the Maint. Department between 8:00 am and 4:00 pm at 573-785-3338 or cell number 573-772-0050